

WASTEWATER DEPARTMENT
WORK REPORT

Jan 7th – Jan 22nd, 2019

Perform daily operation and maintenance of the Wastewater facility. Attend monthly JPC meetings. Tri-weekly SPS (Sewage Pump Station) checks. Water dig and sewer dig N. Jackson St completed and lines repaired. Chemical orders placed and chemical deliveries taken. Take W. primary and E. contact chambers offline for winter. Pump out W. primary and clean. Repairs to camera truck completed and put back in service. Go over engineers proposals for Clute Park. Mini plant inspection done by the DEC, no issues. Call from DEC on Woodstock 50, re strategies etc. Clean CL17 screens. Rebuild chute for belt press. Meet with Mynard about poles and service to new wastewater plant. Meet with Brad Sick go over Montour Falls lift station plans. Meeting for Engineer scoring for Clute Park. Demolition meeting 9th St.

Regards
Terry Wilcox