

WASTEWATER DEPARTMENT
WORK REPORT

April 15th – May 7th, 2019

Perform daily operation and maintenance of the Wastewater facility. Attend monthly JPC meetings. Tri-weekly SPS (Sewage Pump Station) checks. Attend bi-weekly construction meeting for both the new plant and lift station. Repair c117s. April 19th storm flows plant manned all night. Replace batteries and starter on the plant generator, test afterwards. Sewer back-up 2nd street, homeowner issue. Chemical orders and deliveries. Repair drain valve for south clarifier. Drain and repair south clarifier. Pricing for labs to take sludge to landfill. Numerous ufpos for the month of April due to construction on both Magee St and Rt 14 project. Vehicle and equipment inventory completed for WW plant. Onsite numerous times on Magee St for force main install and gravity sewer cleaning.

Regards
Terry Wilcox