

WATER DEPARTMENT
DAILY WORK REPORT

April 15 – May 6, 2019

Performed daily operations, U.F.P.O's. Changed empty chlorine tank. Spent time with Sealand and Vacri projects. New analyzers installed and calibrated. Replaced gate in effluent valve in plant, inspected inside of valve and old gate for wear, very little present. Bouille electric did more work in plant. New Stenner pump now working at alum station. Called on status of ordered flow meters. New entry point monitoring station now operational. Getting quotes for new chlorinator. Ordered parts for RPZ valves. Turned on water service on N. Summit. Made a list of all larger priced equipment for office. Ordered brass from Blair Supply.