

WASTEWATER DEPARTMENT
WORK REPORT

Dec 18th – Jan 7th, 2018

Perform daily operation and maintenance of the Wastewater facility. Attend monthly JPC meetings. Tri-weekly SPS (Sewage Pump Station) checks. DMR and Ops reports completed and submitted to DEC for the month of December. Camera and jet S. Jackson St. UFPO sent in for Jackson St to do main repair and water dig. Meet with Dept. Labor re: confined space training (set up for January 23rd). Meet with LDG re: study grant. Inspect 300 N. Monroe St. complaints of suds on the ground. Inspect the main all clear. Greg L. will address with homeowner. To 503 Perry St, sewer back up, homeowner issue. Work on camera truck, alternator issues. Storm flows December 22nd, ed and myself in till 430 am. Assist Parks Dept. Dock removal. 13.349 million gallons f sewage treated for the month of December.

Regards
Terry Wilcox