

WASTEWATER DEPARTMENT
WORK REPORT

Dec 15th, 2020 – Jan 4th, 2021

- Operation and maintenance of WW facility
- Daily and weekly samples
- Daily lab testing
- UFPOs
- Vouchers done
- Ops and DEC reports completed for November and submitted to DEC and EPA
- Sludge removal
- Moving of old plant to new plant (ongoing)
- List of equipment compiled for insurance (ongoing)
- Organizing of Ops and Maintenance manuals for new plant (ongoing).
- Numerous alarms from Watkins lift station (SCADA issues)
- Manhole cleaning on Porter St, and grease removal out of wet well in Watkins Station.
- Storm flows Dec 24th and 25th plant manned all night.
- Work with LDG on alarming issues in plant, SCADA issues, Fluidyne issues (ongoing).
- Sewer back up 704 Magee St., homeowner issue.
- Lateral inspect Monroe St (Jeffs onsite services)
- Arrange with DEC for plant inspection on Jan 20th.

Regards
Terry A Wilcox