

WASTEWATER DEPARTMENT
WORK REPORT

Jan 4th, 2020 – Jan 19th, 2021

- Operation and maintenance of WW facility
- Daily and weekly samples
- Daily lab testing
- UFPOs
- Vouchers done
- Ops and DEC reports completed for November and submitted to DEC and EPA
- Sludge removal
- Moving of old plant to new plant (ongoing)
- Creation of 2021 operational spreadsheets
- Pull pump at Salt Point Road lift station for rebuild. Replace with spare pump.
- Emergency UFPO 310 8th St.
- Heat trace testing, bad unit isolated
- AHU3 bad heating coil, leaking water into woman's bathroom, isolated for repairs
- Alarming issue with Decatur St lift station, Flyght in to repair
- DEC inspection set for Jan 20th
- Meet with Elk Environmental to get quote on cleaning wet well at Watkins lift station
- Meet with Auqalogics over SCADA issues in plant
- Meet with Streeter over punch list for plant.
- Wasting valves repaired, order 2 from Fluidyne
- AHU #5 full of water, Larson and J&K notified, in plant on Friday Jan 8th to address
- Training of Nick (Collections, Ongoing)
- Cleaning of EQ basins
- Unplugging of 4 in drain lines for screw press
- Flush Porter St from 6th to 9th St
- Sewer back-up 806 Magee St, homeowner issue

Regards
Terry A Wilcox