

WASTEWATER DEPARTMENT
WORK REPORT

Jan 18th, 2021 – Feb 1st, 2022

- Operation and maintenance of WW facility
- Monthly JPC meetings
- Daily and weekly samples
- Daily lab testing
- Vouchers Time sheets
- Work on year end report for DEC
- Rail install for sludge bin
- Termination meeting for WW OIT
- Ops report and DMR completed for December and submitted
- Level sensor faults at Clute Park SPS 1/21 and 1/22 all night
- Heating issues at plant, frozen pipes in blower rm, damage to sprinkler system
- Call from sheriff, and fire alarm company of flow in fire alarm system
- Davis Ulmer in plant assessing damage to sprinkler system 1/24
- Dean Hillyard in plant to assess damage to sprinkler system and heating unit issues
- Numerous calls to J and K over heating units in plant not working as intended
- Goeky Compton in plant to assess unit heater sizing for blower room, will be quoting and installing larger unit heaters
- Call to John Osborne (Schuler Haas) over electrical panels and inspection due to possible water damage from broken pipes
- Email and discuss with Flyght to rewire Clute Park SPS, install floats and remove vacuum level control (freezing issues in extreme cold weather)
- Order and receive skid ice melt for plant
- Deicing and snow removal in plant
- Receive bottles and call lab over Covid sampling in influent coming to plant, 8-week testing period (ongoing)
- Arrange staffing for Saturdays due to staffing shortage in plant
- Email LDG over industrial pretreatment and new sewer use law
-

Regards
Terry A Wilcox