

SUPERINTENDENTS/  
WASTEWATER DEPARTMENT  
WORK REPORT

Jan 22nd – Feb 4th, 2019

Perform daily operation and maintenance of the Wastewater facility. Attend monthly JPC meetings. Tri-weekly SPS (Sewage Pump Station) checks. Confined space training completed. Assist St. Dept. with snow removal. Clean DO probes. Attend meeting for Clute Park RFPs. Work on the RFPs for Street lighting. Repair the check valve in primary sludge pit. Work on tank inspection prices for H<sub>2</sub>O storage tanks. Attend meetings with the DOH for both the Town Dix and the Village Watkins Glen. NYPA phone conference. Participated in phone conference over RFP for street lighting. Flush main on 4<sup>th</sup> St. from Jerlandos to Decatur St. Replace belts on belt press (broken). Work on Street lighting count off of the updated prints from DOT. Discuss with Brad from LDG on rerouting the force main from new lift station. Return empty cylinder of acetylene to Praxair. Quote and req done for replacement belts on the belt press. Emergency water and electric shut off at 2 N. Franklin St. due to a broken sprinkler system (Jan 31<sup>st</sup>). Line isolated and power restored to unaffected parts of the building with power remaining off on the WGI side of building due to electrical components being saturated. @in trash pump repaired due to rag build up on mechanical seal.

Regards  
Terry Wilcox