

WASTEWATER DEPARTMENT
WORK REPORT

Feb 2nd, 2020 – Feb 16th, 2021

- Operation and maintenance of WW facility
- Daily and weekly samples
- Daily lab testing
- UFPOs
- Vouchers done
- Ops and DEC reports completed for December and submitted to DEC and EPA
- Annual flow report and treatment chemical usage completed and submitted to DEC
- Sludge removal
- Repairing of plow truck
- Chemical orders placed (phosphorous removal chemical)
- Snow removal various days
- Pump failures on admin building lift stn, Siewert in plant to fix
- Scada work
- VFD failure on AHU #@, and Renzor heater in blower room, J&K plumbing in to fix
- High EQ tank and SBR failed to advance Feb 11th 12:30am (pump airlocked)
- Work with LDG and Sue Hilton on Industrial pretreatment and extension letter to DEC
- Wet testing completed for first quarter on plant Effluent.

Regards
Terry A Wilcox