

WASTEWATER DEPARTMENT
WORK REPORT

March 1st, 2021 – March 15th, 2022

- Operation and maintenance of WW facility
- Monthly JPC meetings
- Daily and weekly samples
- Daily lab testing
- Vouchers Time sheets
- UFPOs
- Year-end report done and submitted to DEC
- Wet testing results in for all 4 quarters letter from DEC plant passed no further Wet testing till 2026.
- Copper and Covid testing done
- LDG in plant (SPEDES renewal and heating issues)
- Emptying of partial polymer barrels
- Clean Press room floor, clean up all polymer
- Tear apart polymer system, dismantle pressure reducing valve, clean filterers, reassemble x2 reinstall
- Contact Jones specialty Group re water line replacements (Upsizing to 2 in line). Discuss filtration unit for non-potable water going to polymer system.
- BDP in plant to work on screw conveyor, would not run. Disconnect low water cutoff from polymer system due to issues shutting down press during operation
- Sewer complaint 407 12th St. homeowner issue.
- Attend GBEC conference in Buffalo 3/8/22
- High flows 3/7 from rain and snow melt
- Chemical delivery (2500 gallons phosphorous removal chemical).
- Polymer delivery unloaded
- Plant 2022-23 budget submitted to Treasurer and Dean Hillyard (Montour Falls)
- Pricing with Dean on replacement truck for WW plant (to be submitted to JPC) at next meeting.

Regards
Terry A Wilcox