

WASTEWATER DEPARTMENT
WORK REPORT

Mar 18th – April 1st, 2019

Perform daily operation and maintenance of the Wastewater facility. Attend monthly JPC meetings. Tri-weekly SPS (Sewage Pump Station) checks. Paint Decatur St lift station and service supply air blowers. Attend meeting with LDG and Vacri on forcemain installation. Pricing on sewer jetting Magee St for Vacri. Kick off meeting with MRB group for CBDG grant. Unplug digester decant tubes, full of rags. Replaced backup batteries for the chlorine system controller. Receive quote for replacement Flyght pump at Clute Park SPS, order pump. Chemical deliveries. Numerous onsite meetings with Vacri on lift station and forcemain. Meeting with contractor to flush Magee St. Awaiting quotes.

Regards
Terry Wilcox