

WASTEWATER DEPARTMENT
WORK REPORT

March 16th 2019 – April 7th, 2020

Perform daily operation and maintenance of the Wastewater facility. Attend monthly JPC meetings. Attend weekly managers meetings. Tri-weekly SPS (Sewage Pump Station) checks. Attend bi-weekly construction meetings for both plant and lift stations. Ops report, DMR and yearly sludge production completed and sent to DEC. Clean water test completed on new lift station. Repair and test generator behind Village Office. Clean and transfer CL2 tanks. Flush sewer 1004 Decatur St. Lay out trees to be planted along access road to new Wastewater Plant. Chemical orders and deliveries taken. Dealing with foaming issue in digesters. Short staffed due to mandatory staff reduction. Try sodium bicarbonate in digesters to combat foaming. Call with Rural Water over foaming issue, extra samples taken to test phosphates coming into plant. Pick up trees for Magee St and access road.

Regards
Terry Wilcox