

WASTEWATER DEPARTMENT
WORK REPORT

April 5th, 2021 – April 19th, 2022

- Operation and maintenance of WW facility
- Monthly JPC meetings
- Daily and weekly samples
- Daily lab testing
- Vouchers and Time sheets
- UFPOs
- New polymer testing (ongoing)
- Meet with codes over issue at 306 N. Glen
- Sewer complaint 306 N. Glen home owner issue, numerous calls from residents and to homeowner to fix. Fixed 4/14/22
- New bottles in to resume viral testing in plant by Syracuse University, another 8 weeks of testing
- Clean and start UV to test for disinfection season starting 5/1/22
- Dig safe training 4/7/22
- Cleaning of EQ tanks for upcoming disinfection season
- Plant tour given to new County Executive
- Clean DO probes and adjust air due to pin-floc
- Meet with John King Re Industrial pretreatment program
- Meet with Dean and Rhonda and finalize plant budget. Voted on by JPC and accepted.
- Quote received for new plow truck presented to JPC and accepted.
- Onsite with Shrier Martin rep at Montour Falls lift station
- Pull number 1 and 2 pumps at Montour falls to inspect rail guide, #1 pump flipped over due to guide failure. Test pumps, replace #1 pump with spare pump from the plant and send out to Shrier Martin for repairs.
- Overflow sludge tanks, clean up
- Discuss emergency response plan, industrial pretreatment, and sewer use bylaw with LDG.

Regards
Terry A Wilcox