

WASTEWATER DEPARTMENT
WORK REPORT

April 19th, 2021 – May 3rd, 2022

- Operation and maintenance of WW facility
- Monthly JPC meetings
- Daily and weekly samples
- Daily lab testing
- Weekly samples taken to UPS for University of Syracuse
- DMR and OPS reports completed and submitted to DEC and EPA for month of March
- Vouchers and Time sheets
- UFPOs
- Grass cutting
- Sludge removal
- Numerous calls from DEC over SPEDES renewal application
- Discuss with LDG (Brad Sick) SPEDES renewal, install of new filter at WW plant, Industrial pretreatment and sewer use bylaw
- Meet with Regional Equipment (Ken Torotti) over replacement truck for WW plant
- Pick up repaired hydraulic cylinder for lift truck
- F350 in for inspection
- F150 to dealer for repairs, computer issues and inspection
- Meet with Parks laborer over possibility of applying for open WW position
- Dix power failure 4/19 lift station
- Draining of SBR 3
- Order and take delivery of 2300 gallons epic58 (phosphorous removal chemical)
- Order polymer
- Arrange with slack to take all empty polymer drums for disposal (12 empty drums)
- Email JP Yager for quote on filter cloth replacements
- Email Flyght over SCADA issues at lift stations ongoing
- Numerous pump fails at Rock Cabin Montour notified
- Sewer back up 246 Lee rd, homeowner issue
- Order 4 drums new polymer from Slack after plant testing
- Eq blower high discharge temp alarms (ongoing), possible sensor issue
- Scrap clean up to take to scrap yard
- Go over equipment list from Clerk for insurance renewal

Regards
Terry A Wilcox