

WASTEWATER DEPARTMENT
WORK REPORT

April 20th, 2020 – May 4th, 2021

- Operation and maintenance of WW facility
- Daily and weekly samples
- Daily lab testing
- Training of OIT (ongoing)
- UFPOs
- Vouchers done
- Ops and DEC reports completed for March and submitted to DEC and EPA for both Old and New plant
- Sludge removal
- Chemical order placed for 4 drums polymer and return of 3 drums plus 6 empties
- EQ tanks cleaned
- Math and Chemistry course held in plant conference room.
- Jones Specialty group in plant, go over piping changes needed to prevent water hammer and upsize polymer system feed water.
- All portable pumps and equipment removed from old Wastewater site and transported to new plant.
- Sewer back up Monroe St, homeowner issue.
- Contact Larson Design re all sprayers inoperable on new sludge press, quotes for replacements coming.
- UV tested and running for start of disinfection season (May 1st to Nov 1st)
- Pricing from Hach for solids analyzer and BDP for Nozzle replacement on sludge press, reqs done for signing.
- Both tertiary filters and housings cleaned
- Remove nozzles from press to clean, reinstall, 84 total.
- Start transferring equipment from old ambulance to new ambulance (ongoing).
- High flows 4/29 and 4/30

Regards
Terry A Wilcox