

WASTEWATER DEPARTMENT
WORK REPORT

May 4th, 2021 – May 18th, 2021

- Operation and maintenance of WW facility
- Daily and weekly samples
- Daily lab testing
- Training of OIT (ongoing)
- UFPOs
- Vouchers done
- Ops and DEC reports completed for March and submitted to DEC and EPA for both Old and New plant
- Second quarter wet testing started entire week 5/10 to 5/14th
- Chemical delivery (Alum)
- Start repairs on Ferris mower (ongoing)
- Setting up of ambulance with camera etc (ongoing)
- Inspect hills and flats for infiltration (ongoing)
- Sludge removal
- Grass cutting weed eating
- Plugged sewer Seneca St, line flushed 5/8
- High flows 5/9,5/10,5/11
- Replace tubing chemical pump 1, order replacement tubing for pumps
- Clean EQ tanks
- Meeting with Fluidyne over plant issues
- Set up jar testing for polymer for 5/20
- Participate in webcast with WEF
- Zoom meeting with LDG, Fluidyne over settling issues in plant (5/13)
- Clean and repair manhole 117b infiltration
- Jar testing of alum (ongoing)

Regards
Terry A Wilcox