

WASTEWATER DEPARTMENT  
WORK REPORT

April 21st 2019 – May 19th, 2020

Perform daily operation and maintenance of the Wastewater facility. Attend monthly JPC meetings. Attend weekly managers meetings. Tri-weekly SPS (Sewage Pump Station) checks. Attend bi-weekly construction meetings for both plant and lift stations. Ops report, DMR completed for month of April and submitted to DEC and EPA. Storm flows April 30<sup>th</sup> to May 2<sup>nd</sup>. Electrical failure at Walmart pump station and pump one failure at Walmart lift station. Pump 1 pulled at Walmart lift station and sent to Flyght for rebuild. Chlorine contact chambers cleaned. All staff in to assist Parks department with yard work for the week of May 11<sup>th</sup> to 15<sup>th</sup>. . Meet with LDG to go over SCADA screens for new WWTP. Sewer flushed 1006 Decatur St. Training started on systems in the new WWTP. Pick up masks in Wayne County that were supplied by FEMA. Replace battery on Godwin pump (needed during storm). Unplug sludge tubes in primary clarifiers. Grass cutting in plant and lift stations.

Regards  
Terry Wilcox