

WASTEWATER DEPARTMENT
WORK REPORT

June 2nd 2019 – June 16th, 2020

Perform daily operation and maintenance of 2 Wastewater facilities. Attend monthly JPC meetings. Attend weekly managers meetings. Tri-weekly SPS (Sewage Pump Station) checks. Attend bi-weekly construction meetings for both plant and lift stations. Sewer back up 2nd and Franklin, flush line and clean manhole. Training on Generator in Montour Falls, UV system and Chemical systems in new plant. Onsite for bypass pumping and force main hook ups to new lift station on Porter St. 7/1/20 nuisance alarms all night from Decatur St. lift station. 6/27 high flows at old plant, assist in operation of new plant. Supplies ordered for new plant lab testing. 7/2 10:30 am entire Village flow now being sent to the Catherine Valley Water Reclamation Facility.

Regards
Terry Wilcox