

WASTEWATER DEPARTMENT
WORK REPORT

July 1st, 2021 – Aug 3rd, 2021

- Operation and maintenance of WW facility
- Daily and weekly samples
- Daily lab testing
- Training of OIT (ongoing)
- UFPOs
- Vouchers done
- Sludge removal
- Techline i/p phone repair
- New UV unit delivered
- Work on old UV unit, Tech in plant replace 2 coolant pumps
- High flows 7/16 and 7/17
- DMR completed for June and submitted to DEC
- Numerous bar screen alarms
- Numerous Perry St alarms
- Jeffs in plant clean Perry St wet well and plant wet well
- Bath Superintendent in plant for tour
- High level alarm WGPS and plant pump station
- High flows and flooding 7/20
- Decant valve limits adjusted
- Clean influent and uv building from flooding
- Jim Ryan in plant (Mayor Montour Falls) for tour
- Meet with Dean and Greg over SCADA issues in plant
- Draining of SBR 3 to get ready for NASCAR
- Camera 2nd St and Porter Sts for infiltration study
- Meet with Rob (Schuler Haas) over electrical hook ups for new UV unit and gate
- Meet with Streets supervisor over speed limit sign install on access road to plant
- WET testing results received, sent to DEC and LDG
- Prepping for next round of sampling for industrial pretreatment program
- Go over Fire Academy lift station with Flyght over deficiencies
- Go over deficiencies with Cam (Flyght) and telemetry WG lift stations

Regards
Terry A Wilcox