

WASTEWATER DEPARTMENT
WORK REPORT

July 16th – Aug 6th, 2019

Perform daily operation and maintenance of the Wastewater facility. Attend monthly JPC meetings. Tri-weekly SPS (Sewage Pump Station) checks. Attend bi-weekly construction meetings for both plant and lift stations. Daily site visits to new WWTP and Magee St. Replace Miltronics unit for the raw pumps at the plant. Chemical deliveries taken. Submit both Ops report and DMR to EPA and DEC. Blower filters changed. Polymer system set up for race weekend. Extra sludge haulage done for race weekend. Meet with Larue for backflow form completion. Set portable sampler up to grab samples for race weekend. Pipe orders. Meet with Montour, Municipal Solutions, Lonnie, Rhonda over budgeting for new plant. Power bumps July 30th. Flooding on Magee St, call Larson to address. Hosing and cleaning of clarifiers. DEC inspection Aug 2nd at plant. Meeting with LDG over SCADA submittals for new WWTP.

Regards
Terry Wilcox