

WASTEWATER DEPARTMENT  
WORK REPORT

Aug 4th 2019 –Aug 18th, 2020

Perform daily operation and maintenance of 2 Wastewater facilities. Attend monthly JPC meetings. Attend weekly managers meetings. Tri-weekly SPS (Sewage Pump Station) checks. Attend bi-weekly construction meetings for both plant and lift stations. Decommissioning of old plant emptying of tanks, pumping of tanks taking equipment offline, sludge haulage. Operation of new facility (CVWRF). Walkthroughs completed for Watkins and Montour lift stations with Vacri and LDG, punch lists made up. Walkthrough in new WWTP with Streeter, HMI, J&K, Schuler Haas and LDG, punch lists made up. Sewer odor complaint Seneca St. (made to Town of Reading), inspected main running clear. Sewer backup 14<sup>th</sup> St. and 10<sup>th</sup>, jetted line. Sewer backup Reading Rd., homeowner issue. Sewer back up 405 Porter St, homeowner issue.

Regards  
Terry Wilcox