

WASTEWATER DEPARTMENT  
WORK REPORT

Aug 6th – Aug 20th, 2019

Perform daily operation and maintenance of the Wastewater facility. Attend monthly JPC meetings. Tri-weekly SPS (Sewage Pump Station) checks. Attend bi-weekly construction meetings for both plant and lift stations. 15in pipe ordered for entire block of 5<sup>th</sup> to 4<sup>th</sup> on Magee St. Bypass pumping on Magee St, ongoing due to gravity collapsing. Digester blower issue, awaiting tech to test VFD and motor. 4 hr checks on bypass pump 8/14, 8/15. To new construction with Mayor on Salt Point Rd. Storm flows Aug 15<sup>th</sup> Magee and plant.

Regards  
Terry Wilcox