

WASTEWATER DEPARTMENT
WORK REPORT

Aug 18th 2019 –Sept 1st, 2020

Perform daily operation and maintenance of 2 Wastewater facilities. Attend monthly JPC meetings. Pumping down of digesters in old WWTP. Repair Godwin 6in pump, Godwin onsite (blown water pump). Start cleaning of new WWTP from construction (punch list item). Punch lists made up with all contractors, starting to address issues. Continue transferring of equipment from old plant (ongoing). Pictures taken of belt press with LDG to try to sell. Work with Brad (LDG) on creating new spreadsheets for the new plant (ongoing). Chemical deliveries taken. Assist with moving of spare parts for new WWTP. Ops and DMR done for month of July and submitted. Start disposing of old files etc. from old plant. Ordering of supplies (office, etc.). Numerous UFPOs. Inspect and pump wet well at old plant as needed. New sewer hook-up Reading Rd.

Regards
Terry Wilcox