

WASTEWATER DEPARTMENT
WORK REPORT

Aug 20th – Sept 3rd, 2019

Perform daily operation and maintenance of the Wastewater facility. Attend monthly JPC meetings. Tri-weekly SPS (Sewage Pump Station) checks. Attend bi-weekly construction meetings for both plant and lift stations. Test and pull 75hp motor for blowers and send to KJ electric for further testing. Give spare PH meter and probe to Montour Falls WWTP. Unplug grit system. Drain East CL2 chamber. Power fail Village wide Aug 25th, man wastewater plant. Quotes received for replacement 75 hp motor, KJ electric lowest price. Camera Magee St, 4 repairs needed. Cleaning and camera work Aug 30 by Vacri from 9th to under creek on Magee St. done. Meeting with Vacri, NYSEG, LDG, Edger on Aug 27th for coordination of paving and curb replacement. Request for prices for new tracks and lights for sewer camera.

Regards
Terry Wilcox