

WASTEWATER DEPARTMENT  
WORK REPORT

Aug 17th, 2021 – Sept 2nd, 2021

- Operation and maintenance of WW facility
- Daily and weekly samples
- Daily lab testing
- Training of OIT (ongoing)
- UFPOs
- Vouchers done
- Sludge removal
- Chemical orders and deliveries
- Reset pump 3 Montour Falls SPS (Trip)
- Change filters in AHU for Admin Building
- High flows 8/19,20, 21,22
- Third quarter WET testing completed, week of 8/23 to 8/27
- DMR and ops report completed and submitted for month of July
- CPR training all Wastewater staff
- Register 2 plant personnel for courses at Morrisville
- Tubing replacement on chem feed pumps 1 and 2
- List of deficiencies made and emailed to Flyght for outlaying lift stations
- SCADA tech onsite all day 8/31 for lift stations (WGPS and MFPS) as well as plant issues
- Milltronics issues and low-level alarms all nigh 9/1-9/2 at WGPS clean ultrasonic head, hose station
- Repairing of infiltration at Suit Kote lift station
- Arrange with outside contractor for Porter to be camera and cleaned 9/7
- Pricing of new camera for collections, old on crapped out (30 yrs old)

Regards  
Terry A Wilcox