

WASTEWATER DEPARTMENT
WORK REPORT

Oct 1st – Oct 15th, 2019

Perform daily operation and maintenance of the Wastewater facility. Attend monthly JPC meetings. Tri-weekly SPS (Sewage Pump Station) checks. Attend bi-weekly construction meetings for both plant and lift stations. To Shannon and 12th Street to address homeowner complaint. Meet with Edger on tree roots in way of new curbing. Oil changes completed on all primary pumps. S. Clarifier drained and repaired. Repair sewer camera. Onsite for concrete pour at new WWTP. Staff training Oct 8th for Brad and Ed. Meet with LaRue over doors for new WWTP. Ops report and DMR completed for month of September. Oil changes completed on all raw sewage pumps. Onsite Magee St for new curb install. DOL training on prevailing wages.

Regards
Terry Wilcox