

WASTEWATER DEPARTMENT  
WORK REPORT

Oct 19th, 2021 – Nov 2nd, 2021

- Operation and maintenance of WW facility
- Daily and weekly samples
- Daily lab testing
- DMR and OPS report completed and submitted September
- Training of OIT (ongoing)
- UFPOs numerous for tree planting
- Vouchers done
- Sludge removal
- Notify Montour Falls of pump failure at Rock Cabin lift station (numerous)
- Draining and cleaning of SBR 3
- Order place for sludge detector
- Order placed for chemicals (alum)
- Meet with CUEs rep over camera replacement (sewer)
- Order placed for new cable for sewer camera
- Assist streets on jetting storm sewer N. Monroe
- Contact General Control Systems over lift station and plant issues with SCADA
- New UV unit commissioned
- High flows 25<sup>th</sup>,26<sup>th</sup>,27<sup>th</sup>,28<sup>th</sup>.29<sup>th</sup> of October
- High level alarm Central Asphalt station, School personnel contacted to address flow from bathhouses
- Notify Montour Falls of high levels at 2 of their lift stations
- Delivery taken of new manhole lids
- Blower 3 failure, investigate and repair
- Preparing plant for rains on 29<sup>th</sup> and 30<sup>th</sup>, still in high flow

Regards  
Terry A Wilcox