

WASTEWATER DEPARTMENT
WORK REPORT

Dec 2nd, 2020 – Dec 15th, 2020

- Operation and maintenance of WW facility
- Daily and weekly samples
- Daily lab testing
- UFPOs
- Ops and DEC reports completed for October and submitted to DEC
- Sludge removal
- Moving of old plant to new plant (ongoing)
- List of equipment compiled for insurance (ongoing)
- Fluidyne training Dec 8th
- Organizing of Ops and Maintenance manuals for new plant (ongoing).
- Meet with Chemung County operators (upcoming construction), give tour of plant
- Test kits ordered (Hach)
- Power fail at Walmart lift Station, elect addressing issues on pole. Pump wet well down once repaired.
- Numerous alarms from Watkins lift station (SCADA issues)
- Steve Griem in plant (Rural Water).
- Reps from Lakeside in plant, bar screen issues
- Meet with Jeff (Jeffs onsite services) over lateral replacement on Monroe, Division St.
- Arrange for manhole cleaning on Porter St, and grease removal out of wet well in Watkins Station.
- Numerous calls, emails to GCS over SCADA issues.

Regards
Terry A Wilcox