

WATER DEPARTMENT
DAILY WORK REPORT

January 5, 2021 – January 18, 2021

Performed daily operations, U.F.P.O's. Changed empty chlorine tank. Got quotes and prepared requisition for replacement chlorine sensor. Received THM, HAA reports and PIC, POC, SOC reports. Turned off water at 315 N. Glen, 347 Howard, 208 N. Monroe. Changed bad meter base at 116 Eleventh St. Removed temporary contractor water meter at Jefferson Village Project. Went to old wastewater plant to look at removing some items. Darrin took measurements of door at Padua pumping station. Discussed backflow device at county building with maintenance guys. Work in Town of Dix pump houses has been completed. Started gathering information for Annual Water Quality and Water Withdrawal reports. Repaired leak on Ninth St. Received new chlorine sensor for water plant. Tested accuracy of Franklin St. pump station meter with Hydrostatic meter of sales rep. (village meter reading approx. 9% less than sales rep. meter.