

WATER DEPARTMENT  
DAILY WORK REPORT

January 21, 2020 – February 3, 2020

Performed daily operations, U.F.P.O's. Changed empty chlorine tank. Repaired small leak on 8" main feeding former Padua property. Boil water notice lifted after 2 consecutive negative water tests. Worked on budget. Worked on annual water quality report. Talked to ARC about upgrading water meters. Worked with Sarah on letter about businesses with older meters. Spent time looking at Clute Park project drawings. Working on hydrant on Salt Point Rd.