

WATER DEPARTMENT  
DAILY WORK REPORT

February 4, 2020 – February 17, 2020

Performed daily operations, U.F.P.O's. Changed empty chlorine tank. Worked on budget. Finished annual water quality report. Sent to DOH to go over. Finished Water Withdrawal Report and E mailed. Still working on hydrant on Salt Point Rd. Waiting on parts. Work continues on SCADA and communications for water plant. Assisted during massive fire. Water tank levels remained good during event. Filled or topped off fluid in Dix pumps. Repaired circumference break to 8" water main on East Fourth St. A boil water notice was NOT required. Drew THM and HAA samples also monthly Bac - t samples.