

WATER DEPARTMENT
DAILY WORK REPORT

January 21 – February 3, 2019

Performed daily operations, U.F.P.O's. Changed empty chlorine tank. Repaired major leak in upper system on Steuben St. over 330000 gallons lost. Break started about 1 a.m. repair started at 6 a.m. and finished at 9: 40 pm. Boil water notice issued for entire Reading, Village area. Amended later only upper system and upper Reading system to stay on BWN. Code red also used. Consulted with DOH numerous times. Samples drawn on 2/11 & 2/12, all samples negative. Boil water lifted 2/13. John Rekczis started training for C water license, he passed with a score of 94.9. Monthly samples and THM & HAA samples drawn.