

WATER DEPARTMENT  
DAILY WORK REPORT

February 18, 2020 – March 2, 2020

Performed daily operations, U.F.P.O's. Changed empty chlorine tank. Worked on budget. Work continues on SCADA and communications for water plant. Assisted contractor with 4" water service for new Jefferson Village building also discussed changing position of storm basin for project. Diagnosed air compressor found problem and ordered replacements. Loaded scrap metal and took to scrapyard. Went to managers meeting. Checked high read at DOT (billing error). Activated flow meter in pit at Steuben Street tank.