

WATER DEPARTMENT
DAILY WORK REPORT

February 18 – March 3, 2019

Performed daily operations, U.F.P.O's. Changed empty chlorine tank. Meter readings completed for the month. Met with Maltz rep. to place order for new analyzers and go over installation plans. Getting final quote for chemical feed pump installation and other electrical work, going over as soon as possible. Replacing feed lines and drain lines to all turbidimeters, then calibrated. Working at high level pump station, changed plumbing to accommodate new analyzers. Refaced wall with plywood for mounting analyzers. Started going through tools within department. Checked on several high water complaints. Received report from Tim Steed on liquid chlorine use for zebra mussel control. Preparing for DOH visit 3/5 to 3/7.