

WATER DEPARTMENT
DAILY WORK REPORT

March 3, 2020 – March 15, 2020

Performed daily operations, U.F.P.O's. Changed empty chlorine tank. Worked on budget. Work continues on new SCADA and communications for water plant. Ordered and received chemical delivery. Flow meter for back wash installed. Wired both water plant flow meters to new system, village water system now unhooked from old SCADA. Installed water service for rental property of 302 N. Jackson. While doing this job a gas main was damaged, NYSEG was called to repair. Installed water ERT to remodeled ARC building water meter.