

WATER DEPARTMENT
DAILY WORK REPORT

April 1 – April 14, 2019

Performed daily operations, U.F.P.O's. Changed empty chlorine tank. More Contractors coming and going. John Rekczi has completed all water training (93% Avg.). Sealand had trouble tapping 12" main, water department assisted. Met with Vacri reps on flow testing line for new wastewater facility. Water quality report to be finished soon. Met with Tim Steed a few times. New discussions about new Padua tank. Went to 309 Fourth St. for flooding in basement. Repaired leak in main line to Padua tank. This leak remained hidden for many months with losses estimated at 36,000 gallons a day. Service line from Steuben St. tank effluent into high level pump station working, new sink installed for new sample point. Turned on water 107 South Ave. Spent time at new wine and cheese building. Turned on water hauler station for season.