

WATER DEPARTMENT  
DAILY WORK REPORT

May 7 – May 20, 2019

Performed daily operations, U.F.P.O's. Changed empty chlorine tank. Spent time at Sealand and Vacri projects. Bouille Electric finished all electrical work for installation of new chemical feed pumps. Installed new water service at 4 Orchard. Annual water quality report finally approved by Department of Health. Monthly bac-t samples drawn, also quarterly THM, HAA samples. Steuben St. Tank inspection completed. Reduced pressure zone (RPZ) check valves being rebuilt. New flowmeters for water plant have been delivered to Siemens in Corning, scheduling installation date. Investigated large water usage (high school).