

WATER DEPARTMENT
DAILY WORK REPORT

June 1 – June 15, 2020

Performed daily operations, U.F.P.O's. Changed empty chlorine tank. Worked on change from gas to liquid chlorine feed for zebra mussel control at raw station, liquid now operating. Final pump at WGI station running, some adjustments to drive may still be needed. Drew quarterly special federal samples. (2nd round) SCADA system in Dix upgrade nearly complete. Ordered and received chemicals for water production. Discussed new water service for 2600 C.R. 17 with town of Dix. Patched roof on Seneca Lodge Pressure Station. Worked on Dix pump and tank settings. Drew June bac-t samples. Gathered flow data for Second St. building project. Checked on water service repair 505 Magee.