

WATER DEPARTMENT
DAILY WORK REPORT

June 4 – June 17, 2019

Performed daily operations, U.F.P.O's. Changed empty chlorine tank. Checked hydrants after firemen flushed some. Checked on small leak on Fairgrounds Lane. Another tank and SCADA meeting. Changed filters for new analyzers in lab. Received THM, HAA results. Repaired small leak on Fairgrounds Lane. Business Park tank in Dix was drained, serviced, refilled and put back into service. New Stenner pump installed at corrosion control station and put in service. Met with Vacri as they flushed, then pressure tested and super chlorinated new water line to WWTP.