

WATER DEPARTMENT  
DAILY WORK REPORT

June 18 – July 1, 2019

Performed daily operations, U.F.P.O's. Changed empty chlorine tank. Dug up wet spot on Old Corning Rd. (old pipe draining run off). Town of Dix contractors installed new pumps at Franklin St. and South Tank pump stations. Repaired curb box to 600 Division St. DOH rep. came to question John about his skills for receipt of licenses. Another Padua tank meeting. Got quotes for damage to 2014 ford. ( was rear ended )