

WATER DEPARTMENT
DAILY WORK REPORT

June 16 – July 7, 2020

Performed daily operations, U.F.P.O's. Changed empty chlorine tank. SCADA system in Dix upgrade nearly complete. State Park finished filling pool. Discussed new water service for 2600 C.R. 17 with town of Dix. Checked on water service repair 505 Magee. John assisted on Third St. sewer job. Water main break county route 17 Dix, large rock on pipe made crack that eventually blew out a hole. This high-pressure leak caused an older pipe on Willow Ave. to leak. Both repaired. Boil water issued for 5 residents on Willow. New turbidimeter stopped working was temporarily replaced with older one until it can be repaired or replaced. Still having a few minor glitches in Dix system. Aqua Logic will address.