

WATER DEPARTMENT  
DAILY WORK REPORT

June 18 – July 1, 2019

Performed daily operations, U.F.P.O's. Changed empty chlorine tank. Another Padua tank and SCADA meeting. New water tank completed, water main progressing. Electricians began work at water plant. Drew monthly samples. Spent time at 2<sup>nd</sup> St. and Magee St. Alum pump stopped, used alternate. Ordered replacement motor for alum pump. Stanley rebuilt. RPZ check valves at plant bad. Ordered replacements. Checked water complaint on N. Jackson. Flushed hydrant there. Took delivery of material for water plant work and stored. Checked water flow on Orchard Ave. (spring water)