

WATER DEPARTMENT BI-WEEKLY REPORT, 7/6/21 – 7/19/21

Daily operations, UFPO's. Drew PFOA & PFOS samples. Repaired leak on Porter Street, ordered new chlorine scales, scale 1 on old scale stopped working but got it working again. Still replacing it. Color coding recently installed fire hydrants. Checked accuracy of new TOPS meter. Kept extra attention on Dix pumps during SAHLENS weekend. New meter base taken to Wildflower café (replumbing building). Spent more time at plant due to all the rain. Drew monthly bac-t samples. Ordered and received chemicals. Repaired water meter at Frog Hollow.