

WATER DEPARTMENT  
DAILY WORK REPORT

August 6 – August 19, 2019

Performed daily operations, U.F.P.O's. Changed empty chlorine tank. Contractor doing final hookups on W. Second Street at Orchard. New services for 5 customers. 2 new valves installed at intersection. Contractor hit service on Magee St, shut off and retired. THM and HAA samples drawn. Aeration and mixing systems turned on at both new Padua and Business Park tanks. These are to help lower THM, HAA samples. Street Dept. installing culvert piping into creek at plant. This will stop backwash water from overflowing behind Steuben St. tank. (listed by DOH) Monitoring wet spot on W. Second St. Met with MRB Group on PER study. Flushed out intersection of Orchard and W. Second St.