

WATER DEPARTMENT
DAILY WORK REPORT

August 18 – September 1, 2020

Performed daily operations, U.F.P.O's. Changed empty chlorine tank. Ordered and received chemicals. THM, HAA samples drawn. Installed water service at 2600 CR17. Assisted customer with service at 2308 SR 414. Turned off and back on water services at 115 12th St. and 100 Grandview for repairs. Repaired curb box for 2" service on CR17. Spent time at 705 Perry (water, sewer issue). Aqua Logic stopped for some minor glitches and install new replacement turbidimeter. Communicated with Stantec on park project. Turned on water and provided new meter base at 407 6th St. Responded to emergency UFPO at 802 N. Porter. (gas leak) Contacted Sparling instruments about repairing flow meter at Seneca Lodge pressure station. 1 monthly bac-t sample failed in Reading district #2, took 3 additional samples from area, all were good. Tapped water main and installed water service on N. Reading Rd.