

WATER DEPARTMENT
DAILY WORK REPORT

September 4 – September 16, 2019

Performed daily operations, U.F.P.O's. Changed empty chlorine tank, had valve insertion placed on 5th St. The valve insertion did not work, looking into possibility of abandoning 4" main. Found additional valves in that area. Looked at replacement of hydrant in front of laundromat taken out in accident. More work at plant, installing fiber optics, old culvert at bottom of plant driveway removed and replaced by street department. Assisted state park in extending water main for their project. Blue-green algae found in the area, DOH came and drew samples. Placed cap on curb stop for Thai Elephant water service. Tested valves in Magee St. area.