

WATER DEPARTMENT  
DAILY WORK REPORT

September 2 – September 22, 2020

Performed daily operations, U.F.P.O's. Changed empty chlorine tank. Ordered and received chemicals. Getting quotes for fencing around water facility. Drew monthly bac-t samples. All samples good. Communicated with Larsen Design Group and a conference call about village water mains. Waiting on orders from Gottogo Electric and Sparling Instruments. Win 911 out briefly but back in service. Received rebuilt turbidimeter, was replaced with a new one now we have a good spare. Attended managers meeting. Ordered risers for dix paving job and cleaned out and repaired valve box.